



Dolan Chemical Laboratory
4001 Bixby Road
Groveport, OH 43125
T: 614-836-4221, Audinet 210-4221
F: 614-836-4168, Audinet 210-4168
<http://aepenv/labs>

Water Analysis

Location: Mountaineer Plant

Report Date: 10/16/2012

CPS Effluent

Sample Number: 124377-001

Date Collected: 10/08/2012 07:45

Date Received: 10/10/2012

Parameter	Result	Units	RL	MDL	Analysis By	Analysis Date/Time	Method
Bromide, Br	28.9	mg/L	5	1	TDF	10/15/2012	EPA 300.1
Selenium, Se	395	ug/L	0.5	0.1	DPC	10/15/2012 14:39	EPA 200.8
Chloride, Cl	3560	mg/L	20	5	TDF	10/15/2012	EPA 300.1
Fluoride, F	64.5	mg/L	1	0.2	TDF	10/15/2012	EPA 300.1

CPS Effluent

Sample Number: 124377-002

Date Collected: 10/10/2012 07:50

Date Received: 10/10/2012

Parameter	Result	Units	RL	MDL	Analysis By	Analysis Date/Time	Method
Bromide, Br	27.6	mg/L	5	1	TDF	10/15/2012	EPA 300.1
Selenium, Se	441	ug/L	0.5	0.1	DPC	10/15/2012 14:43	EPA 200.8
Chloride, Cl	3520	mg/L	20	5	TDF	10/15/2012	EPA 300.1
Fluoride, F	65.9	mg/L	1	0.2	TDF	10/15/2012	EPA 300.1

A handwritten signature in black ink that reads 'Brian S. Snyder'.

Brian Snyder, Chemist II

Email bssnyder@aep.com

Tel. 614-836-4224

Fax 614-836-4168

Audinet 210-4224

THIS TEST REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL WITHOUT WRITTEN APPROVAL OF THE LABORATORY. ALL TEST RESULTS MEET ALL OF THE REQUIREMENTS OF THE ACCREDITING AUTHORITY, UNLESS OTHERWISE NOTED.